

Regarding Registration LA20046
NE 20-9-36 W4M

Water Well Monitoring Requirements

The purpose of this statement is to outline the water well monitoring requirements in Registration LA20046. The Water well monitoring condition of Registration LA20046 reads:

“The permit holder shall sample and test raw groundwater from water well #291327 (located in front of the residence), according to water well monitoring requirements prescribed by the NRCB in writing. The NRCB may, based on the monitoring results and at its discretion, revise those requirements from time to time, in writing.”

Appendix B, of Decision Summary LA20046 concluded that, while an exemption from the 100 meters water well setback is warranted, to provide further protection for users of the water well, an exemption is granted on the condition that the applicant must periodically test the raw well water. Therefore, the water well monitoring requirements for this CFO shall be as follows:

Monitoring Frequency

Annually, with results submitted to the NRCB by July 31 of each year

Water Well Test Parameters

Chlorides and nitrate-nitrogen

Water Wells to be used for Monitoring

Well number ID# 291327 located in front of the residence

This monitoring requirement become effective on the date of this letter.

Date: January 22, 2021

(Original signed)
Carina Weisbach
Approval Officer