



NRCB

Natural Resources
Conservation Board

Provincial Building, #201, 10008 – 107 Street
Morinville, Alberta T8R 1L3
T 780-939-1212 Toll Free 310-0000
www.nrcb.ca

Regarding Approval BA22005
E½ 27-59-1 W5M

Water Well Monitoring Requirements

The purpose of this statement is to outline the water well monitoring requirements in Approval BA22005.

Operating Condition #3 of Approval BA22005 reads:

4) **Water Well Testing Reporting**

The co-permit holders shall sample and test raw groundwater, according to water well monitoring requirements prescribed by the NRCB in writing. The NRCB may, based on the monitoring results and at its discretion, revise those requirements from time to time, in writing. (See BA22005 Water Well Monitoring Statement)

Condition #3 updates and carries forward a water well monitoring condition from Authorization BA05003. For this reason, the water well monitoring requirements for this CFO shall be as follows:

Monitoring Frequency

Annually, with results submitted to the NRCB by October 31 of each year

Water Well Test Parameters

Chlorides and nitrates

Water Wells to be used for Monitoring

As determined by inspector

Well numbers:

ID 418255

ID 492450

ID 498119

These monitoring requirements become effective on the date of this letter and supersede any previously issued water well monitoring requirements at this facility.

June 22, 2023

(Original signed)

Nathan Shirley
Approval Officer