



Regarding Approval RA24042  
SW-22-040-27-W4

### **Water Well Monitoring Requirements**

The purpose of this statement is to outline the water well monitoring requirements in Approval RA24042. Operating Condition 14 of Approval RA24042 reads:

*“The co-permit holders shall sample and test raw groundwater on an annual basis, from water well ID 283528, according to the water well monitoring requirements prescribed by the NRCB in writing (“Sampling for Water Well Monitoring” Fact Sheet). The NRCB may, based on the monitoring results and at its discretion, revise those requirements in writing. (See RA24042 Water Well Monitoring Statement)”*

The NRCB has assessed the water well monitoring requirements, using results from an environmental risk screening conducted on March 11, 2025, for this confined feeding operation.

Based on the screening results, the NRCB has determined that the water well monitoring requirements for this facility should be as follows:

#### **Monitoring Frequency**

Annually, with results submitted to the NRCB by July 31 of each year

#### **Water Well Test Parameters**

Chlorides and nitrate-nitrogen

#### **Water Wells to be used for Monitoring**

WW ID 283528

These monitoring requirements become effective on the date of this monitoring statement.

April 23, 2025

(Original signed)

Sarah Neff  
Approval Officer