



Regarding Approval RA25024  
NE 3-39-06-W5

### **Water Well Monitoring Requirements**

The purpose of this statement is to outline the water well monitoring requirements in Approval RA25024. Operating condition 4 of Approval RA25024 reads:

*“The permit holder shall sample and test raw groundwater on an annual basis, from water well ID 456022 and water well ID 456021 according to the water well monitoring requirements prescribed by the NRCB in writing (“Sampling for Water Well Monitoring” Fact Sheet). The NRCB may, based on the monitoring results and at its discretion, revise those requirements in writing. (See Water Well Monitoring Requirements)”*

The NRCB has re-assessed the water well monitoring requirements, using results from an environmental risk screening conducted on June 13, 2025, for this confined feeding operation.

Based on the screening results, the NRCB has determined that the water well monitoring requirements for this facility should be as follows:

#### **Monitoring Frequency**

Annually, with results submitted to the NRCB by September 30<sup>th</sup> of each year

#### **Water Well Test Parameters**

Chlorides and nitrate-nitrogen

#### **Water Wells to be used for Monitoring**

Water well ID 456022 and 456021

These monitoring requirements become effective on the date of this statement and supersede any previously issued monitoring requirements at this facility.

June 18, 2025

(Original signed)

Sarah Neff  
Approval Officer